

# Construction Products Regulation 2011: Declaration of Performance

LIT-DOP-KM060/KM065/KM035/WH900/TBH100  
Page 1 of 1

DoP Number:	COASTAL0012
Date of Issuance:	8 <sup>th</sup> April 2022
Unique Identifier Product Code:	KM060/KM065/KM035/WH900/TBH100
Intended Use or Uses:	For use on doors when fitted in accordance with manufacturer's instructions
Name of Manufacturer:	Coastal Specialist Ironmongery Ltd., Global House, Bojea Industrial Estate, St Austell, PL25 5RJ, UK
System of assessment product as set out in CPR, Annex V:	System 1
Harmonised Standard:	BS EN 1906:2012

## Declared Performance

Operating Efforts	
Number of Cycles	200,000 cycles
Force L - Downward	100 N
Force P - Outward	100 N
Force R - Return	20 N
Testing Parameters	KM060/KM065/KM035/WH900/TBH100 Lever handle was fitted to a plywood block as specified in EN 1906 » the handle was categorised as a spring assisted handle » Test method: <b>Test 6 of EN 1906 - 200,000 cycles</b>
Durability	» <b>Passed a 200,000 cycle test with EN 1906:2012 Test 6, Durability Grade 7</b>
Dangerous Substances	The materials in the product do not contain or release any dangerous substances in excess of the maximum levels specified in existing European material standards or any national regulations.

Signed for and on behalf of the manufacturer by:



**Mr Loren Jenner**  
Managing Director  
Coastal Specialist Ironmongery Ltd



**Mr Lloyd Pinckston**  
Head of Product & Innovation  
Coastal Specialist Ironmongery Ltd